



Member of the FM Global Group

FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

***XAMINAR XR-a-E-HVbNcdefg. Valve Positioner***

NI / I / 2 / ABCD / T4 Ta = -10°C to 70°C; Type 4/IP67

a = Control type: A or C  
b = Valve type: ROD, RRD, LOD, LRD, ROM, RRM, LOM, LRM  
c = Conduit: N\*, M\*, Q, P  
d = Solenoid: 1, 2  
e = Valve manifold: NA, BA, NS, BS  
f = Special Features: 0, 1, 2  
g = Bluetooth: 0, B

\* *Special Condition for use;*

*Conduit options N and M are for use with user supplied cable glands. The end user must use cable glands listed by an OSHA certified NRTLs and are sized for the cables used.*

### Equipment Ratings:

Suitable for Class I, Division 2, Groups A, B, C, and D

### FM Approved for:

Westlock Controls Corp.  
280 Midland Avenue, Saddle Brook, NJ 07663 USA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3611	2004
Class 3810	2005
ANSI/NEMA 250	1991


Original Project ID: 3031525

Approval Granted: *May 27, 2008*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

  
\_\_\_\_\_  
J. E. Marquédant  
Group Manager, Electrical

*27 May 2008*  
\_\_\_\_\_  
Date



Member of the FM Global Group

FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

***XAMINAR XR-a-E-HVbNcdefg. Valve Positioner***

NI / 1 / 2 / ABCD / T4 Ta = -10°C to 70°C; Type 4/IP67

a = Control type: A or C  
b = Valve type: ROD, RRD, LOD, LRD, ROM, RRM, LOM, LRM  
c = Conduit: N\*, M\*, Q, P  
d = Solenoid: 1, 2  
e = Valve manifold: NA, BA, NS, BS  
f = Special Features: 0, 1, 2  
g = Bluetooth: 0, B

*\*Special Condition for use;*

*Conduit options N and M are for use with user supplied cable glands. The end user must use cable glands listed by an OSHA certified NRTLs and are sized for the cables used.*

### Equipment Ratings:

Suitable for Class I, Division 2, Groups A, B, C, and D

### FM Approved for:

Westlock Controls Corp.  
280 Midland Avenue, Saddle Brook, NJ 07663 USA



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

C22.2 No. 213	1987
C22.2 No. 94-M91	1991
C22.2 No. 142-M1987	1987

Original Project ID: 3031525

Approval Granted: *May 27, 2008*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

  
\_\_\_\_\_  
J. E. Marquedant  
Group Manager, Electrical

*27 May 2008*  
\_\_\_\_\_  
Date